



Performance Standard

Templeton Fire Department

TOPIC: HYDRANT CONNECTION

TIME FRAME: 3:00

LEVEL OF COMPLEXITY: Level 2

BEHAVIORAL OBJECTIVE:

Condition: Given E7185 or E7195, full PPE including SCBA, and an operator for assistance

Behavior: Fire personnel will complete a hydrant connection

Standard: 100% accuracy within 3 minutes

PERFORMANCE:

Time will start when fire personnel exits the engine:

- Dismount from the jumpseat and exit the engine
- Mount tailboard
- Grasp 4" LDH supply hose
- Step down and pull hose
- Anchor hose around hydrant (90 deg to the engine)
- Give command to operator "**Lay Line**" (Verbal and Physical Call)
- Assure 100' of LDH is down on ground
- Check 2 ½" hydrant caps
- Flush hydrant
- Make hydrant connection
- Charge supply line when operator signals for water (Airhorn or Visual)

Time will stop when a viable water supply has been established

NOTES:

*****Automatic Fail*****

- Not anchoring hose (around hydrant, or folded in hands)
- Charging line too fast creating water hammer on engine
- If participant is unable to complete standard within the time allotted

Performance standards are designed to assure that all fire personnel are capable of completing the duties assigned to their respective position. All personnel should remember that while engaging in firefighting operations, the order and/or priority of some tasks may be changed by the company officer.



Performance Standard

Templeton Fire Department

Performance standards are designed to assure that all fire personnel are capable of completing the duties assigned to their respective position. All personnel should remember that while engaging in firefighting operations, the order and/or priority of some tasks may be changed by the company officer.