



## Performance Standard

---

Templeton Fire Department

**TOPIC:** PRE-CONNECT DEPLOYMENT

**TIME FRAME:** 1:15

**LEVEL OF COMPLEXITY:** Level 1

**BEHAVIORAL OBJECTIVE:**

**Condition:** Given a fire engine, full PPE including SCBA (mask not in place), a flat area, and an operator for assistance

**Behavior:** Fire personnel will deploy the attack line and flow water

**Standard:** 100% accuracy within 1 minute and 15 seconds

**PERFORMANCE:**

**Time will start when fire personnel dismounts the engine:**

- Dismount the engine from a jumpseat
- Deploy assigned hoseline to predetermined location 75' from engine
- Signal operator that you are ready for water by stating **"Ready for Water"** (Verbal and Physical Call)
- Open nozzle, adjust nozzle pattern to narrow fog, and close nozzle

**Time stops when fire personnel shuts down nozzle**

- Assist with draining and re-loading of the hoseload (not included in time standard)

**NOTES:**

\*\*\*Automatic Fail if:\*\*\*

- Not clearing all hose from hosebed
- Loss of control of hose loops
- Loss of control of nozzle
- Unable to reload hoseload correctly
- If participant is unable to complete standard within the time allotted

*Performance standards are designed to assure that all fire personnel are capable of completing the duties assigned to their respective position. All personnel should remember that while engaging in firefighting operations, the order and/or priority of some tasks may be changed by the company officer.*