



Performance Standard

Templeton Fire Department

TOPIC: PUMPING A GROUND MONITOR

TIME FRAME: 3:00

LEVEL OF COMPLEXITY: Level 3

BEHAVIORAL OBJECTIVE:

Condition: Given a Type 1 fire engine, and a firefighter for assistance

Behavior: Fire personnel will pump a ground based monitor

Standard: 100% accuracy within 3 minutes

PERFORMANCE:

Time will start when the Air Brakes are set:

- Set brakes
- Engage pump
- Exit cab
- Chock rear wheels (Front and Back)
- Open tank fill
- Obtain supply with soft suction
- Mark gauges
- Supply Ground Montior with proper pressure
- Re-mark gauges
- Fill and Isolate tank
- Continue to flow for 1 minutes

Time Stops after 1 minute of accurate flowing

- Shutdown and restore engine to road condition

Line 1&2 100' feet of 2 1/2 inch, Flow 500 GPM = _____ EP
**2 ½ lines will be stretched prior to evolution*

NOTES:

Automatic fail

- Pressure exceeds 10 psi (+/-) range
- Unable to acquire an accurate flow within the time given

Performance standards are designed to assure that all fire personnel are capable of completing the duties assigned to their respective position. All personnel should remember that while engaging in firefighting operations, the order and/or priority of some tasks may be changed by the company officer.